

OFFICE OF ATMAKUR MUNICIPALITY  
WANAPARTHY DISTRICT



Lr.No.ATK/MCPL/F1106/2026

Dt: 04.05.2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Ch. Shashidhar, Municipal Commissioner** from Atmakur Municipality inspected the **M.V. Raman High School (CBSC)** on 03.03.2026 and found that the **M.V. Raman High School (CBSC)** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of (04) years

Commissioner

Atmakur Municipality

Wanaparthy Dist.

Ch. Shashidhar

Municipal Commissioner

Atmakur Municipality

Wanaparthy District

To:

M.V. Raman High School (CBSE)

Atmakur (A) Wanaparthy Dist

Telangana (State)

CHAIRMAN

**M.V. RAMAN HIGH SCHOOL**

Affiliated to CBSE No. 3630248

Atmakur (A), Wanaparthy Dist

Telangana State

PRINCIPAL

**M.V. RAMAN HIGH SCHOOL**

Affiliated to CBSE No. 3630248

Atmakur (A), Wanaparthy Dist

Telangana State.

GOVERNMENT OF TELANGANA  
DISTRICT LEVEL WATER QUALITY MONITORING LABORATORY  
MB-INTRA, SUB-DIVISION :: WANAPARTHY  
Chemical analysis report : IS 10500-2012



Date of Collection		Date of testing : 28-02-2026													
Sl. No	Name Of the District	Name Of the Mondal	Name Of the Grama panchayati & Habitations	Location	Source	PH limits between 6.5-8.5	Total Dissolved Solids Desirable limit 500 mg/lit & Permissible limit 2000 mg/lit	Total Alkalinity as Caoco3 Desirible limit 200 mg/lit & permissible limit 600 mg/lit	Total Hardness as Caoco3 Desirible limit 300 mg/lit & permissible limit 600 mg/lit	Total Chloride as Caoco3 Desirible limit 250 mg/lit & permissible limit 1000 mg/lit	Fluoride as Desirible limit 1.0 mg/lit & permissible limit 1.5 mg/lit	Nitrate as No3 Desirible limit 45 mg/lit & permissible limit No relaxation	Sulphate as So4 Desirible limit 200 mg/lit & permissible limit 400 mg/lit	Iron as fe Desirible limit 0.3 mg/lit & permissible limit 1.0 mg/lit	Remarks
	Wanaparthy	Atmakur	Atmakur	MV Raman School	TAP water	7.91	791	312	376	216	0.62	14.18	58.33	0.21	Satisfactory
	Wanaparthy	Atmakur	Atmakur	MV Raman School	Bore water	7.75	1028	376	408	286	1.02	20.45	80.18	0.42	Satisfactory

  
CHAIRMAN

M.V. RAMAN HIGH SCHOOL  
Affiliated to CBSE No. 3630248  
Atmakur (A), Wanaparthy Dist.  
Telangana State

  
PRINCIPAL

M.V. RAMAN HIGH SCHOOL  
Affiliated to CBSE No. 3630248  
Atmakur (A), Wanaparthy Dist  
Telangana State

  
Water quality Analysis Laboratory  
Rws&s MB (Intra) Division:: Wanaparthy